

Case Study Pump Blockage Problem

Automotive Manufacturing




The Challenge







- The client was experiencing repetitive blockage problems on vertical pumps and was unable to accurately identify and resolve the issue ahead of pump failure
- Sensotek Kappa sensors were installed to monitor machine health and a detailed vibration report was actioned to diagnose the problem
- Automated alarms were set up at each pump, acting to alert the site manager to potential blockages which would break vanes and cause irreparable damage

Analysis




- Peak vibration is a key indicator of impacting in the waveform. The OA Vibration graph plots Peak to Peak data from each machine under surveillance at a site level
- The graph indicates an anomaly at Pump 3, which exhibits significantly more peak vibration at 1.46g vs around 0.5g for the other pumps
- Pump 4 displays periodic peaks at 0.89g

Vibration Spectrum




Analysis



- On closer inspection the Vibration Spectrum depicts a raised noise floor with no clear side bands at approximately 27.9xRPM
- This is within the Lower Harmonic Bearing Frequency Band. Both Peak to Peak and Lower Harmonic Bearing Frequencies provide indication of suspected faults occurring at Pump 3
- This could be evidence of
 - Cavitation
 - Debris
 - Surges in liquid supply




Action



- Maintenance inspection of the pump identified the culprits of blockage problems

← The items pictured were removed from the pump

PEAK-TO-PEAK DATA



Result




- With debris removed Peak to Peak vibration fell to within normal levels
- The raised noise floor in the lower harmonic bearing frequency disappeared


Conclusion

- By detecting debris blockages early, irreparable pump breakage is avoided
- Machine Health Monitoring was implemented on all 80 pumps site-wide

SPECTRUM



SPECTRUM





FURTHER INFORMATION

Customer Support

RMS Ltd. No.42 Goldcrest Close. Longridge Park.

Colchester. Essex CO4 3FN.

Company Reg No. 03808313. VAT No. GB 741737428.

Tel/Fax: +44 (0)1206 791917

Email: info@rms-reliability.com

rms-reliability.com